

Questions Received on Wayfinding Signage Bids as of 10.12.2021

BID SUBMITTAL QUESTIONS

1. The City of Kaukauna is a tax exempt organization. We will provide a certificate of exemption upon awarding of bid.
2. Bids must be delivered in hard copy format (sealed) either by mail or in-person drop-off.
3. There is no bond for this project. Please leave line item on bid worksheet blank.
4. Certificate of insurance is only required if bid is awarded.

DESIGN INTENT QUESTIONS

5. A 3rd party engineer stamp is not required if sign fabricator self-engineers designs.
6. Sign Type A1-A4 (Page 10-11, Sheets 2-3): Curved signs should be bid as acrylic or PVC or HDU. Flat signs should be bid as the same material, with an alternate for aluminum. These signs are not illuminated.
7. Breakaways are not required on all post and panel sign types. They are only included on signs that are on higher speed roadways (and not in the lower speed downtown area). Implement the type of breakaway connections normally used by your team.
8. Sign Type D1 (Page 25, Sheet 17): Internal lighting has already been upgraded to LED.
9. Sign Type B5 (Page 22, Sheet 14): The alternate post is a single faced sign.
10. Sign Type D2 (Page 26, Sheet 18): The second side of this sign is the same verbiage as side one.
11. Sign Type D4 (Page 28, Sheet 20): The die cut panel should be mounted flush to the post with no visible fasteners.
12. Sign Type E1 (Page 29, Sheet 21): The FERC panels should be on both sides of each monument sign where indicated. This FERC panel is only on select signs.

SIGN LOCATION QUESTIONS

13. Sign E1-001- Lambie Field Sign at Riverside Park is not removed
14. Sign E1-002 – Existing sign with electrical will only be there while the adjacent building is being redeveloped as a temporary power source. The new sign location will be adjusted slightly to address this.
15. Sign E1-008 – Gerow Field Sign at Horseshoe Park is not removed
16. Sign E3-007 – Veteran's Memorial Ring of Honor brick guide will not be removed.
17. Sign Location E3-008 – Two educational signs "Living River" at Thilwerth Park will not be removed.
18. Kaukauna Public Library post and panel sign at intersection of Island and Thilmany will be removed, but not replaced.
19. Sign Location F1-002 – Konkapot Trail map sign will not be removed.
20. Sign Location G1-001 – Existing post and panel sign on McDonald's property / terrace is to be removed.